



Test laboratory accredited according to ISO 17025 by the Swiss Accreditation Service SAS
 Laboratoire d'essai accrédité selon ISO 17025 par le Service d'accréditation suisse SAS
 Prüflabor akkreditiert nach ISO 17025 durch die Schweizerische Akkreditierungsstelle SAS

Registration number
 Numéro d'accréditation
 Akkreditierungsnummer

STS 024

Schweizerischer Prüfstellendienst
 Service suisse d'essai
 Swiss testing service



Report:	Electromagnetic compatibility		Report no:	13-MO-0313.10
Product name:	AKLKK-900		Dossier no:	13-MO-0313
Serial no:	A2021001292	Model number:	AKLKK-900	
Customer:	Air-On AG Gewerbstrasse 11 6330 Cham Switzerland	Date of test:	September 3 - 4, 2013	

Standards		Result
EN 50491-5-1	(Home and Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS) - requirements, conditions and test set-up)	Pass
EN 50491-5-2	(HBES - Residential, commercial and light industry environment)	Pass
EN 50491-5-3	(HBES - Industry environment)	Pass
EN 61000-6-1 / -3	(Residential)	Pass
EN 61000-6-2 / -4	(Industrial)	Pass

Test performed by

Mr Klaus Woweries
 EMC test-engineer

Report prepared by

Mr Klaus Woweries
 EMC test-engineer

Report controlled and approved by

Mr Christophe Perrenoud
 Technical director

Rossens, October 9th, 2013

(Issue Date)

REV201306xx

Main language : English

The present document results from tests on one specimen and does not prejudice to the conformity of all the manufactured products.

t:\auftragsablage pq\auftragsablage ih-mo\2013\300-399\13-mo-0313_air-on_aklkk-900\4 prüfberichte\13-mo-0313.10_air-on_aklkk-900.docm

Electrosuisse, SEV Association for Electrical Engineering, Power and Information Technologies

Montena EMC
 route de Montena 75
 1728 Rossens
 Switzerland
 phone +41 26 411 93 33
 fax +41 26 411 93 30
 www.montenaemc.ch
 office@montenaemc.ch

Montena EMC
 Technopark Blumenegg
 Blumeneggstrasse 50
 9403 Goldach
 Switzerland
 phone +41 71 278 41 92
 fax +41 71 278 41 93

Montena EMC
 Ringstrasse 10
 5432 Neuenhof
 Switzerland
 phone +41 56 290 30 35
 fax +41 56 290 38 33

Montena EMC
 Postfach 1315
 3072 Ostermündigen
 Switzerland
 phone +41 79 256 21 55